



City of Pawtucket, RI

\*\*\*\*\* Addendum #1 \*\*\*\*\*

## **RFP # 26-019 - Chain Link Fence and Other Related Appurtenances**

May 21, 2026

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the Request for Proposals indicated above. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in, and form a part of the proposed Contract Documents for the work.

Inclusion of this Addendum must be acknowledged in the spaces provided in the document entitled "Request for Proposals 26-019 - Chain Link Fence and Other Related Appurtenances". Failure to acknowledge any and all addenda in the above specified bid form may be cause for rejection of the bids by the Owner on the grounds that it is not responsive.

This addendum consists of two (2) pages.

### **Item 1: Questions and Answers:**

Q1: In the details in Appendix C: Fence Specifications, it calls out for the posts to be Galvanized Schedule 40 Steel Pipe. Cosco is requesting that Galvanized SS-40 Steel Pipe be used in lieu of Galvanized Schedule 40 Steel Pipe. The reasons for this requested change are: 1) SS-40 Steel Pipe is much cheaper than Schedule 40 Steel Pipe, 2) SS-40 Steel Pipe is stronger than Schedule 40 Steel Pipe, 3) Cosco uses SS-40 Steel Pipe on RIDOT projects and is standard for RIDOT.

A1: PWSB requests that the bid price incorporates the materials specified in Appendix C.

Q2: In the details in Appendix C: Fence Specifications, it calls out for the fence fabric to be Aluminized 9 Gauge x 2" Mesh Fence Fabric. Cosco is requesting that Galvanized 9 Gauge x 2" Mesh Fence Fabric be used in lieu of Aluminized 9 Gauge x 2" Mesh Fence Fabric. The reasons for this requested change are: 1) Galvanized Fence Fabric is much cheaper than Aluminized Fence Fabric, 2) Cosco uses Galvanized Fence Fabric on RIDOT projects and is standard for RIDOT.

A2: PWSB requests that the bid price incorporates the materials specified in Appendix C.

Q3: In the details in Appendix C: Fence Specifications, it calls out for the barbed wire to be 3 Strand Aluminized 4-Point Barbed Wire. Cosco is requesting that Galvanized 4-Point Barbed Wire be used in lieu of Aluminized 4-Point Barbed Wire. The reasons for this requested change are: 1) Galvanized Barbed Wire is much cheaper than Aluminized Barbed Wire, 2) Cosco uses Galvanized Barbed Wire on RIDOT projects and is standard for RIDOT.

A3: PWSB requests that the bid price incorporates the materials specified in Appendix C.

**\*\* END OF ADDENDUM 1 \*\***



---

Peter Wingate

Purchasing Director